

Our Ref: HL/M130467  
Test Report: MAT/LAB 278E



15<sup>th</sup> February 2013

Hydrogomma SpA.  
Via Delle Industrie2/4,  
Sulbiate (MB),  
Italy

**WATER REGULATIONS ADVISORY SCHEME (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**HOSES & TUBING**

**5140**

SPW hose. White coloured, extruded, thermoplastic elastomeric hose. For use with water up to 85°C.

**APPROVAL NUMBER: 1206573**  
**APPROVAL HOLDER: HYDROGOMMA SPA.**

The Scheme reserves the right to review approval. This approval is valid between June 2012 and June 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in blue ink, appearing to read 'Jason Furnival', is written over a light blue horizontal line.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme